

ANNEXURE I TO STARRED LAQ NO.018A (a)

12 MLD WTP							
Sr no	Drawal raw water pump	Pumping Elevation Pump	Age	Motor	Qty	Replaced / Repaired	Remarks
1	2	3	4	5	6	7	8
1	Mather and Platt PUMP		2 Nos-36 years,1 No 2yrs	Kirloskar	3	Pump replaced 1no (2021), Pumps repaired 2Nos(2021)	Old pumps 2 nos (1986 Model),Repaired Motors 3 nos in 2021
2		WILO PUMP(15 mld)	3 Years	Marathon	3	Replaced in 2019	
30 MLD WTP							
Sr no	Drawal raw water pump	Pumping Elevation Pump	Age	Motor	Qty	Replaced / Repaired	Remarks
1	2	3	4	5	6	7	8
1	Mather and Platt PUMP (25mld capacity)		12 years	Kirloskar	2	Pump repaired in 2021 -1 no	Installed in 2010
2		WILO PUMP (15 Mld capacity)	3 years	Marathon	4	Replaced in 2019	
50 MLD WTP							
Sr no	Drawal raw water pump	Pumping Elevation Pump	Age	Motor	Qty	Replaced / Repaired	Remarks
1	2	3	4	5	6	7	8
1	Mather and Platt PUMP (30 mld capacity)		12 years	Kirloskar	1	Pump repaired in 2021 -1 no	
2		WPIL PUMP (30 mld capacity)		Marathon	3	Pump repaired in 2019 -1 no, Pump repaired in 2021 -1 no	Motor repaired in 2021, Motor sent for repairs in June 2022
SUMMARY							
TOTAL NO. OF PUMPS AT ASSONORA - 16							
TOTAL PUMPS REPLACED -- 8 (7 IN 2019, 1 IN 2021)							